

# CERTIFICATE OF CONFORMITY



**Product** : UPS  
**Brand** : APC  
**Test Model** : SMT3000RMI2U, SMT2200RMI2U, SMT1500RMI2U,  
SMT1000RMI2U, SMT750RMI2U  
**Series Model** : SMT3000RMIXXXXXXXXXXX, SMT2200RMIXXXXXXXXXXX  
SMT1500RMIXXXXXXXXXXX, SMT1000RMIXXXXXXXXXXX  
SMT750RMIXXXXXXXXXXX  
(The X in above models could be 0~9, A~Z or blank for marketing differences.)  
**Applicant** : American Power Conversion Holding Inc, Taiwan Branch  
**Report No.** : C990423D19A R1

We, **Bureau Veritas Consumer Products Services (H.K.) Ltd., Taoyuan Branch**, declare that the equipment above has been tested in our facility and found compliance with the requirement limits of applicable standards. The test record, data evaluation and Equipment Under Test (EUT) configurations represented herein are true and accurate under the standards herein specified.

---

**CISPR 22: 2006, Class A**

---

**AS/NZS CISPR 22: 2006, Class A**

---

**EN 62040-2:2006 / IEC 62040-2:2005 ED. 2.0, Category C2**

---

**Note:** ACMA will accept test reports to later standards where proof of compliance to the following clauses is not required to be demonstrated against:

- Immunity, harmonics and flicker tests

---

Kenny Meng / Assistant Manager

Nov. 15, 2017



No. 47-2, 14th Ling, Chia Pau Vil., Lin Kou Dist., New Taipei City, Taiwan ( R.O.C. )

Tel: 886-2-26052180 Fax: 886-2-26051924

<http://www.bureauveritas-adt.com> E-Mail: [service.adt@tw.bureauveritas.com](mailto:service.adt@tw.bureauveritas.com)

Cancels and replaces the Certificate No.: C990423D19AC dated Aug. 13, 2010